



KERALA WATER AUTHORITY
QUALITY CONTROL SUB DISTRICT LABORATORY
CHIRAYINKEEZHU, ATTINGAL, THIRUVANANTHAPURAM
E-mail - qcsdlcz@gmail.com Phone No:0470 299 1352



Test Report

ULR No: TC10838240000001348F

Test Report No. KWA/QCSDL/CZ/2024/1467


Date of Report : 08/07/2024

| Customer Name & Address | | | 1. Date of Receipt :06/07/2024 | | |
|--|---|------------|---|--|--------|
| SREE GOKULAM PUBLIC SCHOOL ATTINGAL MAMOM PH 9447891788 | | | 2. Sampling done by :The Customer(QUA_149664) | | |
| | | | 3. Sample Code : KWA/QCSDL/CZ/2024/1467 | | |
| | | | 4. Sample Particulars :DRINKING WATER | | |
| | | | 5. Sample Quantity :2 litre | | |
| | | | From :06/07/2024 To :08/07/2024 | | |
| Sl. No. | Characteristics | Unit | Test Method | Acceptable limits as per IS 10500 - 2012 | Result |
| 1 | Turbidity | (NTU) | IS 3025 (Part 10) 2023 Nephelometric method | 1 | 0.26 |
| 2 | pH at 25°C | - | IS 3025 (Part 11) 2022 Electrometric method | 6.5 to 8.5 | 6.89 |
| 3 | Total Hardness (as Ca CO ₃) | (mg/litre) | IS 3025 (Part 21) 2019 EDTA method | 200 | 18.4 |
| 4 | Chloride (as Cl) | (mg/litre) | IS 3025 (Part 32) 2019 Argentometric method | 250 | 17.3 |

Remarks:

1. The results stated above related only to the sample(s) received for testing.
2. This test report shall not be reproduced except in full without the written approval of the Laboratory.
3. Retention Period: 5 days from the date of testing

Analyzed By: 

SANITARY CHEMIST
QUALITY CONTROL SUB DISTRICT LAB
CHIRAYINKEEZHU, ATTINGAL
THIRUVANANTHAPURAM
SIMI E 
Authorized Signatory:

* End of Report *

| | | |
|-------------------|----------------------|------------------------|
| KWA/QCSDL/CZ/R/41 | Issue No:2 | Issue Date: 19/07/2022 |
| Rev.No: 04 | Rev Date: 20/10/2023 | Page 1 of 1 |



KERALA WATER AUTHORITY
QUALITY CONTROL SUB DISTRICT LABORATORY
CHIRAYINKEEZHU, ATTINGAL, THIRUVANANTHAPURAM
E-mail - qcSDLcz@gmail.com Phone No:0470 299 1352

Test Report

Test Report. No. KWA/QCSDL/CZ/2024/1467

Date of Report :08/07/2024

| | | | | | |
|--|-----------------------------------|-----------------|--|---|---------------|
| SREE GOKULAM PUBLIC SCHOOL ATTINGAL MAMOM PH 9447891788 | | | 1. Date of Receipt: 06/07/2024 | | |
| | | | 2. Sampling done by :The Customer (QUA_149664) | | |
| | | | 3. Sample Code : KWA/QCSDL/CZ/2024/1467 | | |
| | | | 4. Sample Particulars : DRINKING WATER | | |
| | | | 5. Sample Quantity :2 litre | | |
| | | | 6. Test Performing Dates | | |
| | | | From :06/07/2024 To :08/07/2024 | | |
| | Characteristics | Unit | Test Method | Acceptable limits as per IS 10500 - 2012 | Result |
| 1 | Electrical Conductivity at 25 0 C | (micro mhos/cm) | IS 3025 (Part 14) -2013 | | 60.77 |
| 2 | Iron (as Fe) | (mg/litre) | IS 3025 (Part 53) - 2003) 1, 10 Phenanthroline Method | 1.0 | 0.05 |
| 3 | Nitrate (as NO3) | (mg/litre) | APHA 23rd Edition 4500 - NO3 - B : 2017 UV Spectrophotometric Screening Method | 45 | 1.38 |


Remarks:-

NB:- 1. The results stated above related only to the sample(s) received for testing.

2. This test certificate shall not be reproduced except in full without the written approval of the Laboratory.

3. Retention Period: 5 days from the date of testing


Analyzed by:

SANITARY CHEMIST
QUALITY CONTROL SUB DISTRICT LAB
CHIRAYINKEEZHU, ATTINGAL
THIRUVANANTHAPURAM

Authorized Signatory:

* End of Report *

| | | |
|-------------------|----------------------|------------------------|
| KWA/QCSDL/CZ/R/41 | Issue No:2 | Issue Date: 19/07/2022 |
| Rev.No: 04 | Rev Date: 20/10/2023 | Page 1 of 1 |



KERALA WATER AUTHORITY
QUALITY CONTROL DISTRICT LABORATORY

VELLAYAMBALAM, THIRUVANANTHAPURAM

Telephone No - 0471-2735303, E-mail - aeequalitytvm@gmail.com

Test Report

Test Report. No -KWA/QCSDL/CZ/2023/1467

Date of Report : 08/07/2024

| Customer Name & Address | | | 1. Date of Receipt : 06/07/2024 | |
|--|-----------------|---|--|--------|
| SREE GOKULAM PUBLIC SCHOOL ATTINGAL MAMOM PH 9447891788 | | | 2. Sampling done by :The Customer (QUA 149664) | |
| | | | 3. Sample Code : KWA/QCSDL/CZ/2023/1467 | |
| | | | 4. Sample Particulars : DRINKING WATER | |
| | | | 5. Sample Quantity :250 ml | |
| | | | 6. Test Performing Dates | |
| | | | From :06 /07/2024 To : 08 /07/2024 | |
| Sl. No. | Parameters | Acceptable limits as per-IS 10500- 2012 | Test Method | Result |
| 1 | Total Coliforms | Shall not be detected / 100ml | IS 15185 : 2016 ISO 9308 - I : 2014 | ABSENT |
| 2 | E. Coli | Shall not be detected/ 100ml | IS 15185 : 2016 ISO 9308 - I : 2014 | ABSENT |


Remarks:-

NB:- 1.The results stated above related only to the sample(s) received for testing

2.This test Report shall not be reproduced except in full without the written approval of the Laboratory.

Analysed By 

BACTERIOLOGIST
Quality Control Subdistrict Lab
Kerala Water Authority
Chirayinkeezhu, Attingal
Thiruvananthapuram

Authorized Signatory 

* End of Report *

| | | |
|-------------------|----------------------|-----------------------|
| KWA/QCDL/TVM/R/41 | Issue No:2 | Issue Date 31.05.2022 |
| Rev.No: 01 | Rev Date: 18/05/2023 | Page 1 of 1 |