



KERALA WATER AUTHORITY

QUALITY CONTROL SUB DISTRICT LABORATORY

Chirayinkeezhu, Attingal, Thiruvananthapuram - 695 101

Telephone : 0470 2991352 Email : qcsdlcz@gmail.com

(NABL Recognized Block Level Government Drinking Water Testing Laboratory)

TEST REPORT

Certificate No. : NABL-DWT-00997

Test Report No: KWA/QCSDL/CZ/2025/763

Date :07/05/2025

Customer Name & Address: SREE GOKULAM PUBLIC SCHOOL, MAMOM, ATTINGAL	
Phone Number : 9947984166	
Date of collection: 29/04/2025	Sampling was done by: The Customer (QUA_223915)
Sample code: KWA/QCSDL/CZ/2025/763	Sample particulars: Drinking Water
Sample quantity: 2 litre	Date of analysis: From: 02/05/2025 To: 03/05/2025

Sl. No.	Characteristics	Unit	Test Method	Acceptable Limit as per IS 10500-2012	Result
1	Turbidity	NTU	IS 3025 (Part 10), Nephelometric Method	1	0.36
2	pH		IS 3025 (Part 11), Electrometric Method	6.5 to 8.5	7.59
3	Total Hardness (as CaCO_3)	mg/l	IS 3025 (Part 21), EDTA Method	200	45.84
4	Chloride (as Cl)	mg/l	IS 3025 (Part 32), Argentometric Method	250	27.40

Remarks:

1. The results stated above related only to the sample received for testing
2. This test report shall not be reproduced except in full without the written approval of the laboratory management.
3. The retention period of the sample is five days from the date of analysis.

Analyzed By: Deepa

Authorized By: DEEPA L.

SANITARY CHEMIST
QUALITY CONTROL SUB DISTRICT LAB
CHIRAYINKEEZHU, ATTINGAL
THIRUVANANTHAPURAM

Self attested
Alloya



End of the report



KERALA WATER AUTHORITY
QUALITY CONTROL SUB DISTRICT LABORATORY
CHIRAYINKEEZHU, ATTINGAL, THIRUVANANTHAPURAM
E-mail - qcsdlcz@gmail.com Phone No:0470 299 1352

Test Report

Test Report. No. KWA/QCSDL/CZ/2025/763

Date of Report :07/05/2025

Customer Name & Address			1. Date of Receipt: 29.04.2025		
SREE GOKULAM PUBLIC SCHOOL MAMOM, ATTINGAL PH 9947984166			2. Sampling done by :The Customer (QUA 223915)		
			3. Sample Code : KWA/QCSDL/CZ/2025/763		
			4. Sample Particulars : DRINKING WATER		
			5. Sample Quantity :2 litre		
			6. Test Performing Dates		
			From : 02.05.2025 To :03.05.2025		
	Characteristics	Unit	Test Method	Acceptable limits as per IS 10500 - 2012	Result
1	Electrical Conductivity at 25°C	(micro mhos/cm)	IS 3025 (Part 14) -2013		178.50
2	Iron (as Fe)	(mg/litre)	IS 3025 (Part 53) - 2003) 1, 10 Phenanthroline Method	1.0	NIL
3	Nitrate (as NO3)	(mg/litre)	APHA 23rd Edition 4500 - NO3 - B : 2017 UV Spectrophotometric Screening Method	45	5.72

Remarks:-

NB:- 1. The results stated above related only to the sample(s) received for testing.

2. This test certificate shall not be reproduced except in full without the written approval of the Laboratory.

3. Retention Period: 5 days from the date of testing

SANITARY CHEMIST
QUALITY CONTROL SUB DISTRICT LAB
CHIRAYINKEEZHU, ATTINGAL
THIRUVANANTHAPURAM

DEEPA E

Analyzed by:

Authorized Signatory:

* End of Report *

KWA/QCSDL/CZ/R/41	Issue No:2	Issue Date: 19/07/2022
-------------------	------------	------------------------



KERALA WATER AUTHORITY
QUALITY CONTROL SUB DISTRICT LABORATORY
CHIRAYINKEEZHU, ATTINGAL, THIRUVANANTHAPURAM
E-mail - qcSDLcz@gmail.com Phone No:0470 299 1352

Test Report

Test Report. No -KWA/QCSDL/CZ/2025/763

Date of Report : 07/05/2025

Customer Name & Address			1. Date of Receipt : 29.04.2025	
SREE GOKULAM PUBLIC SCHOOL MAMOM, ATTINGAL PH 9947984166			2. Sampling done by :The Customer (QUA 223915)	
			3. Sample Code : KWA/QCSDL/CZ/2025/763	
			4. Sample Particulars:DRINKING WATER	
			5. Sample Quantity :250 ml	
			6. Test Performing Dates	
			From :02.05.2025 To : 03.05.2025	
Sl. No.	Parameters	Acceptable limits as per-IS 10500- 2012	Test Method	Result
1	Total Coliforms	Shall not be detected / 100ml	IS 15185 : 2016 ISO 9308 - I : 2014	ABSENT
2	E. Coli	Shall not be detected/ 100ml	IS 15185 : 2016 ISO 9308 - I : 2014	ABSENT

Remarks:-

NB:- 1.The results stated above related only to the sample(s) received for testing.

2.This test Report shall not be reproduced except in full without the written approval of the Laboratory.

BACTERIOLOGIST
Quality Control Subdistrict Lab
Kerala Water Authority
Chirayinkeezhu, Attingal
Thiruvananthapuram

Authorized Signatory

Analysed By

* End of Report *

KWA/QCSDL/CZ/R/41

Issue No:1

Issue Date 18.03.2024

Rev.No: 01

Rev Date: 00.00.00

Page 1 of 1

Self collected

No: PH21/2025

SANITARY FITNESS CERTIFICATE

THIS IS TO CERTIFY THAT SANITARY ARRANGEMENTS MADE BY THE ADMINISTRATIVE OFFICER OF SREE GOKULAM PUBLIC SCHOOL, PARAYATHUKONAM P.O, KIZHUVILAM, MAMOM, ATTINGAL WHICH IS FUNCTIONING IN WARD NO VI BUILDING NO. 139/A, B, C, D, E, F OF KIZHUVILAM GRAMA PANCHAYATH, KIZHUVILAM VILLAGE WERE SATISFACTORY AT THE TIME OF INSPECTION ON 25/04/2025. THIS CERTIFICATE IS VALID UP TO 31/03/2026.

(N.B. THIS CERTIFICATE IS LIABLE TO BECOME INVALID IF ANY VIOLATION OF HYGIENIC CONDITION OR ANY PUBLIC NUISANCE ON THE PART OF FIRM)

PLACE: KIZHUVILAM

DATE: 25.04.2025



[Handwritten Signature]
HEALTH INSPECTOR
P.H.O. KIZHUVILAM

Self attested.
[Handwritten Signature]

[Handwritten Mark]